



## Proposed Code Change

State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

### FOR OFFICE USE ONLY

Received 5/9/09

Code 59-09

#### INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title E3405.6		Page 648
Proponent Charlie Eldridge	Title Consultant	
Address 551 Grassy Ln., Indianapolis, IN 46217		Phone (317) 370-3444
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p><b>E3405.6 Illumination.</b> Artificial illumination shall be provided for all working spaces for service equipment and panelboards installed indoors. <u>Additional lighting outlets shall not be required where the work space is illuminated by an adjacent artificial light source.</u></p>		
REASON AND FISCAL IMPACT		
<p>This text was extracted from the 2005 Indiana Residential Code.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		